gkkworks





WEBSTER ELEMENTARY (K-8)

Assessment Summary:

Another architectural jewel in the district's facility inventory, Webster is in relative good shape but is, nevertheless, in need of upgrading in certain areas. Its Auditorium, Cafeteria and Kitchen need to be brought up to current electrical, mechanical, lighting, acoustical, technological, and interior finish standards.

Other immediate needs are the provision of a new heating system or repair of the existing boiler system; replacement of hallways and exterior drinking fountains with ADA compliant fixtures; replacement of old electrical panel boards; and separation of water meters.

Secondary items include improvement of acoustics in corridors and replacement of the old glued-on acoustical tile system throughout the campus.

A key feature of this school is its parking lot configuration and related drop-off/pick-up system which may be a model for similar installations in other district schools.

2101 E Washington Blvd Pasadena, CA 91104 (626) 798-7866

Year Built:	1927	
Site Acreage:	4.80	
Grade Levels:	K-8	
Enrollment:	579	
Permanent Capacity:	675	
Classrooms:		
Permanent:	27	
Portables:	4	